
From: John A Cima (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=JOHN171D28]
Sent: 1/26/2016 10:36:40 AM
To: Michael A Glagola (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Mic0210]
CC: Michael J Winters (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=MIC1082]; Doug Wight (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Dougl7]
Subject: RE: Possum Toe Drain Separation Drawing
Attachments: PP Ash Pond D - Toe Drain Separation Concept - Wight Comments.pdf

Mike,

Attached are additional comments on the draft GAI Concept Drawing from Doug Wight. He echo's similar concerns about details, especially regarding the pumping system.

Regards,

John

John A. Cima P.E.

John A. Cima, P.E.

Power Generation Engineering

Phone: (804)-273-3045; Cell: (804)-912-5432

From: Michael J Winters (Generation - 34)
Sent: Tuesday, January 26, 2016 8:50 AM
To: Michael A Glagola (Generation - 34); Doug Wight (Generation - 34); John A Cima (Generation - 34)
Subject: RE: Possum Toe Drain Separation Drawing

This is probably fine for DEQ, but needs more detail to be constructed. Maybe already in the works, but GAI needs to provide support details, seal details, anchor details etc.

Mike W

From: Michael A Glagola (Generation - 34)
Sent: Monday, January 25, 2016 2:50 PM
To: Doug Wight (Generation - 34); John A Cima (Generation - 34); Michael J Winters (Generation - 34)
Subject: FW: Possum Toe Drain Separation Drawing

FYI

From: John Klamut [<mailto:J.Klamut@gaiconsultants.com>]
Sent: Monday, January 25, 2016 1:54 PM
To: John Glover; rwilliams@gloverconstruction.com
Cc: Scott Quinlan; Brian Bullock; Michael A Glagola (Generation - 34); John DeBarbieri
Subject: Possum Toe Drain Separation Drawing

John/Reuben,

This is our working drawing for the toe drain separation. We will be sending this to DEQ, please review and provide any edits or comments, we want to be sure what we send them is correct.

Give me a call with any questions.

Thanks,

John

John R. Klamut, P.E.
Engineering Manager

00013038

GAI Consultants, Inc.

4200 Triangle Lane, Export, PA 15632-1358

412.399.5425 | C 724.421.6740 |     



transforming ideas into reality[®] since 1958 | gaiconsultants.com

CONFIDENTIALITY NOTICE: This communication contains confidential information belonging to the sender and may be legally privileged. This communication is solely for the use of its intended recipient. If you are not the intended recipient, inform the sender of the error and remove this email from your system. If this transmission includes any technical information, design data, and/or recommendations, they are provided only as a matter of convenience and may not be used for final design and/or construction.